



CASING SPACER - MODEL CSS12

SPECIFICATION & CERTIFICATE OF COMPLIANCE

The CCI Model CSS12 Casing Spacer shall be constructed of circular Stainless Steel bands, which bolt together forming a shell around the carrier pipe. The casing spacer shall be lined with a ribbed PVC extrusion with a retaining section that overlaps the edges of the shell and prevents slippage. The spacer shall be designed using runners with or without risers to support the carrier pipe within the casing and to maintain a minimum clearance of 1.0 in. between the casing ID and the carrier pipe OD.

The runners shall be Glass Reinforced Polymer with the ends of the runners beveled to facilitate installation over rough weld beads or the welded ends of misaligned or deformed casing pipe. The runners shall be attached to support structures (shell or risers) at appropriate positions to properly support the carrier pipe within the casing and for ease of installation. They shall have a minimum length of 11.0 in. and a minimum width of 2.0 in.

The shell shall be manufactured of 12.0 in. wide, 14-Gauge Stainless Steel. The riser shall be constructed of 10-Gauge Stainless Steel, 10.75 in. minimum lengths with a height to be determined based on the annular space between the carrier pipe OD and the casing ID.

Recommended positioning is to place one casing spacer 1-2 feet on each side of the bell joint and one every 6-8 feet apart thereafter for a total of three casing spacers per carrier pipe joint. CCI engineering reserves the right to recommend spacing according to the application.

PHYSICAL PROPERTIES

SHELL & RISERS

Shell – 14-Gauge Stainless Steel
Risers – 10-Gauge Stainless Steel

FINISH

2B Finish

RUNNERS

2" Wide Glass Reinforced Polymer
Length: 11" (279.4 mm) Minimum
Tensile Strength: ASTM D638 27.0 ksi
Compressive Strength: ASTM D695 33.0 ksi
Flexural Strength: ASTM D790 40 ksi
Izod Impact @ 73°F (23°C): 11 kJ/m²
Melting Point: ASTM D3418 504°F (262°C)

LINER – PVC (EPDM Alternate)

Thickness: 0.09" (2.29mm) Minimum
Hardness: ASTM D2240 Durometer Shore 'A' 80-90
Dielectric Strength: ASTM D149-13 1,000 VPM
Water Absorption: 1% Maximum
Overlaps edges

ASSEMBLY HARDWARE

Bolts: 5/16"-18UNC x 2" Long Stainless Steel
Nuts: 5/16" Stainless Steel Hex
Washers: 5/16" Stainless Steel SAE 2330

WELDING

All risers shall be welded to the shell by MIG welding.
All welds are to be fully passivated.

CCI Piping Systems certifies the Model CSS12 Stainless Steel Casing Spacers are of the highest quality which meet or exceed industry standards.

CCI PIPING SYSTEMS, LLC

1026 O'Neal Drive • Breaux Bridge, LA 70517
ccipipe.com • sales@ccipipe.com
337.332.5808 • 800.867.2772